
CERTIFICATE HEADER

Certificate Name: LEKTEK

Certificate Type: LEKTEK

Prepared by:

A Long

On Behalf of: *(Name & Address)*

Lektek Ltd
Kestrel Court
Waterwells Drive
Waterwells Business Park
Gloucester
GL2 2AT

Prepared For: **Client:** *(Name & Address)*

Location: *(Name & Address)*

Moon Loungers
47 Lower Chapel Lane
Frampton Cotterell
Bristol

BS36 2RQ

Moon Loungers
47 Lower Chapel Lane
Frampton Cotterell
Bristol

BS36 2RQ

Notes: *(If Applicable)*

APPLIANCE TESTING CERTIFICATE PASS

CLIENT AND LOCATION DETAILS

Moon Loungers
47 Lower Chapel Lane
Frampton Cotterell
Bristol

BS36 2RQ

Moon Loungers
47 Lower Chapel Lane
Frampton Cotterell
Bristol

BS36 2RQ

| Asset ID | Description | Room | Test Date | Visual | Cont 1 | Ins. | Oper. | Leak. | Repair | Status |
|----------|----------------|---------|------------|--------|--------|--------|-------|-------|--------|--------|
| ML002 | LAMP | STORAGE | 13/07/2017 | Pass | 0.11 | >99.90 | | | 0 | P |
| ML006 | SPEAKER | STORAGE | 13/07/2017 | Pass | | >99.90 | | | 0 | P |
| ML007 | STAGE LIGHT | STORAGE | 13/07/2017 | Pass | 0.23 | >99.90 | | | 0 | P |
| ML008 | SPEAKER | STORAGE | 13/07/2017 | Pass | | >99.90 | | | 0 | P |
| ML009 | STAGE LIGHT | STORAGE | 13/07/2017 | Pass | 0.23 | >99.90 | | | 0 | P |
| ML010 | PSU LAMP | STORAGE | 13/07/2017 | Pass | | >99.90 | | | 0 | P |
| ML012 | SPEAKER | STORAGE | 13/07/2017 | Pass | | >99.90 | | | 0 | P |
| ML017 | EXT 6WAY | STORAGE | 13/07/2017 | Pass | 0.09 | >99.90 | | | 0 | P |
| ML021 | IEC LEAD | STORAGE | 13/07/2017 | Pass | 0.05 | >99.90 | | | 0 | P |
| ML022 | EQUALISER | STORAGE | 13/07/2017 | Pass | 0.10 | >99.90 | | | 0 | P |
| ML023 | PSU AMPLIFIER | STORAGE | 13/07/2017 | Pass | | >99.90 | | | 0 | P |
| ML024 | PSU MIXER | STORAGE | 13/07/2017 | Pass | | >99.90 | | | 0 | P |
| ML030 | EXT 1WAY | STORAGE | 13/07/2017 | Pass | 0.18 | >99.90 | | | 0 | P |
| ML034 | IEC LEAD | STORAGE | 13/07/2017 | Pass | 0.09 | >99.90 | | | 0 | P |
| ML037 | PSU SOUND DESK | STORAGE | 13/07/2017 | Pass | | >99.90 | | | 0 | P |
| ML042 | IEC LEAD | STORAGE | 13/07/2017 | Pass | 0.06 | >99.90 | | | 0 | P |
| ML043 | IEC LEAD | STORAGE | 13/07/2017 | Pass | 0.07 | >99.90 | | | 0 | P |
| ML045 | IEC LEAD | STORAGE | 13/07/2017 | Pass | 0.09 | >99.90 | | | 0 | P |
| ML046 | AC ADAPTOR | STORAGE | 13/07/2017 | Pass | | >99.90 | | | 0 | P |
| ML051 | SPEAKER | STORAGE | 13/07/2017 | Pass | | >99.90 | | | 0 | P |
| ML052 | SPEAKER | STORAGE | 13/07/2017 | Pass | | >99.90 | | | 0 | P |
| ML053 | AC ADAPTOR | STORAGE | 13/07/2017 | Pass | | >99.90 | | | 0 | P |
| ML054 | AC ADAPTOR | STORAGE | 13/07/2017 | Pass | | >99.90 | | | 0 | P |
| ML055 | IEC LEAD | STORAGE | 13/07/2017 | Pass | 0.11 | >99.90 | | | 0 | P |
| ML056 | EXT 4WAY | STORAGE | 13/07/2017 | Pass | 0.09 | >99.90 | | | 0 | P |
| ML057 | IEC LEAD | STORAGE | 13/07/2017 | Pass | 0.07 | >99.90 | | | 0 | P |
| ML060 | IEC LEAD | STORAGE | 13/07/2017 | Pass | 0.12 | >99.90 | | | 0 | P |
| ML061 | IEC LEAD | STORAGE | 13/07/2017 | Pass | 0.10 | >99.90 | | | 0 | P |
| ML064 | IEC LEAD | STORAGE | 13/07/2017 | Pass | 0.13 | >99.90 | | | 0 | P |
| ML068 | AC ADAPTOR | STORAGE | 13/07/2017 | Pass | | >99.90 | | | 0 | P |
| ML074 | PSU LAMP | STORAGE | 13/07/2017 | Pass | | >99.90 | | | 0 | P |
| ML075 | EXT 4WAY | STORAGE | 13/07/2017 | Pass | 0.11 | >99.90 | | | 0 | P |
| ML076 | IEC LEAD | STORAGE | 13/07/2017 | Pass | 0.07 | >99.90 | | | 0 | P |
| ML077 | IEC LEAD | STORAGE | 13/07/2017 | Pass | 0.11 | >99.90 | | | 0 | P |
| ML080 | EXT 4WAY | STORAGE | 13/07/2017 | Pass | 0.09 | >99.90 | | | 0 | P |
| ML081 | EXT 4WAY | STORAGE | 13/07/2017 | Pass | 0.11 | >99.90 | | | 0 | P |
| ML084 | IEC LEAD | STORAGE | 13/07/2017 | Pass | 0.09 | >99.90 | | | 0 | P |
| ML085 | PSU LAMP | STORAGE | 13/07/2017 | Pass | | >99.90 | | | 0 | P |

**APPLIANCE TESTING
CERTIFICATE
PASS**

CLIENT AND LOCATION DETAILS

Moon Loungers
47 Lower Chapel Lane
Frampton Cotterell
Bristol

BS36 2RQ

Moon Loungers
47 Lower Chapel Lane
Frampton Cotterell
Bristol

BS36 2RQ

| Asset ID | Description | Room | Test Date | Visual | Cont 1 | Ins. | Oper. | Leak. | Repair | Status |
|----------|-------------|---------|------------|--------|--------|--------|-------|-------|--------|--------|
| ML087 | IEC LEAD | STORAGE | 13/07/2017 | Pass | 0.08 | >99.90 | | | 0 | P |
| ML088 | IEC LEAD | STORAGE | 13/07/2017 | Pass | 0.04 | >99.90 | | | 0 | P |
| ML090 | EXT 4WAY | STORAGE | 13/07/2017 | Pass | 0.11 | >99.90 | | | 0 | P |
| ML091 | IEC LEAD | STORAGE | 13/07/2017 | Pass | 0.11 | >99.90 | | | 0 | P |
| ML092 | IEC LEAD | STORAGE | 13/07/2017 | Pass | 0.07 | >99.90 | | | 0 | P |
| ML093 | IEC LEAD | STORAGE | 13/07/2017 | Pass | 0.07 | >99.90 | | | 0 | P |
| ML094 | EXT 6WAY | STORAGE | 13/07/2017 | Pass | 0.06 | >99.90 | | | 0 | P |
| ML095 | EXT 1WAY | STORAGE | 13/07/2017 | Pass | 0.18 | >99.90 | | | 0 | P |
| ML096 | EXT 4WAY | STORAGE | 13/07/2017 | Pass | 0.06 | >99.90 | | | 0 | P |
| ML097 | EXT 2WAY | STORAGE | 13/07/2017 | Pass | 0.19 | >99.90 | | | 0 | P |
| ML098 | EXT 4WAY | STORAGE | 13/07/2017 | Pass | 0.09 | >99.90 | | | 0 | P |
| ML099 | IEC LEAD | STORAGE | 13/07/2017 | Pass | 0.09 | >99.90 | | | 0 | P |
| ML100 | PSU LAPTOP | STORAGE | 13/07/2017 | Pass | | >99.90 | | | 0 | P |
| ML101 | EXT 4WAY | STORAGE | 13/07/2017 | Pass | 0.04 | >99.90 | | | 0 | P |